

Alternative 7

- Add 75 MW/300 MWH of battery energy storage
- Remove all existing units except Unit 9, Unit 9 already complies with Rule 1135 limits with some tuning changes
- Add five Wartsila 18.5 MW internal combustion engine generators – about 93 MWs total
- New Glendale Switching Station



Alternative 7 Visual Simulation

